



[✔ View Certification](#) | [📄 Download COR](#)

## DMR Copy of Submission

**Permit**

**Permit ID:** CTP002421  
**Permittee:** Tweed-New Haven Airport Authority  
**Facility:** TWEED-NEW HAVEN REGIONAL AIRPORT  
**Permitted Feature:** 201 - External Outfall

**Major:**   
**Permittee Address:** 155 Burr Street  
New Haven , CT06512  
**Facility Location:** 155 BURR ST  
NEW HAVEN , CT06512  
**Discharge:** 201-1 - Aircraft Deicing Fluid

**Report Dates & Status**

**Monitoring Period:** From 03/01/23 to 03/31/23  
**Status:** **NetDMR Validated**

**DMR Due Date:** 04/30/23

**Considerations for Form Completion****Principal Executive Officer**

**First Name:** Tom  
**Title:** Executive Director

**Last Name:** Rafter  
**Telephone:** 203-466-8833

**No Data Indicator (NODI)**

**Form NODI:** -

Parameter		NODI	Quantity or Loading			Quality or Concentration				# of Ex.	Freq. of Analysis	Smpl. Type
Code	Name		Value 1	Value 2	Units	Value 1	Value 2	Value 3	Units			
00056	<b>Flow rate</b>	Smpl.	=6000.3		07 - gal/d						01/30 - Monthly	TM - TOTALZ
1 - Effluent Gross												
Season: 0		Req.	Req Mon MO AVG		07 - gal/d						01/30 - Monthly	TM - TOTALZ
NODI: -		NODI										
00310	<b>BOD, 5-day, 20 deg. C</b>	Smpl.	=573.21		26 - lb/d	=386.1	=49000.0	19 - mg/L			01/07 - Weekly	CP - COMPOS
1 - Effluent Gross												
Season: 0		Req.	<=6000.0 DAILY MX		26 - lb/d	Req Mon MO AVG	Req Mon DAILY MX	19 - mg/L			01/07 - Weekly	CP - COMPOS
NODI: -		NODI										
00400	<b>pH</b>	Smpl.				=6.28	=7.26	12 - SU			01/07 - Weekly	R4 - RNG-4A
1 - Effluent Gross												
Season: 0		Req.				>=6.0 INST MIN	<=10.0 INST MAX	12 - SU			01/07 - Weekly	R4 - RNG-4A
NODI: -		NODI										
00530	<b>Solids, total suspended</b>	Smpl.				=19.8	=34.0	19 - mg/L			01/30 - Monthly	CP - COMPOS
1 - Effluent Gross												
Season: 0		Req.				Req Mon MO AVG	Req Mon DAILY MX	19 - mg/L			01/30 - Monthly	CP - COMPOS
NODI: -		NODI										
50047	<b>Flow, maximum during 24 hr period</b>	Smpl.	=9281.8		07 - gal/d						01/30 - Monthly	TM - TOTALZ
1 - Effluent Gross												
Season: 0		Req.	<=36000.0 DAILY MX		07 - gal/d						01/30 - Monthly	TM - TOTALZ
NODI: -		NODI										
61163	<b>Propylene glycol, total</b>	Smpl.				=7800.0	=18000.0	19 - mg/L			01/07 - Weekly	CP - COMPOS
1 - Effluent Gross												
Season: 0		Req.				Req Mon MO AVG	Req Mon DAILY MX	19 - mg/L			01/07 - Weekly	CP - COMPOS
NODI: -		NODI										
61941	<b>pH, maximum</b>	Smpl.					=7.26	12 - SU			99/99 - Continuous	CN - CONTIN
1 - Effluent Gross												



**Submission Note**

If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

**Edit Check Errors**

No errors.

**Comments****Attachments**

No attachments.

**Report Last Saved By****Tweed-New Haven Airport Authority**

User: FSURIEL@FLYTWEED.COM  
Name: Felipe Suriel  
E-Mail: fsuriel@flytweed.com  
Date/Time: 2023-04-10 10:37 (Time Zone:-04:00)

**Report Last Signed By**

User: FSURIEL@FLYTWEED.COM  
Name: Felipe Suriel  
E-Mail: fsuriel@flytweed.com  
Date/Time: 2023-04-10 10:38 (Time Zone:-04:00)