

# DMR Copy of Record

**Permit #:** CTP002421  
**Permittee:** Tweed-New Haven Airport Authority  
**Facility:** TWEED-NEW HAVEN REGIONAL AIRPORT  
**Major:** No  
**Permittee Address:** 155 Burr Street  
 155 BURR ST  
 NEW HAVEN, CT 06512  
**Discharge:** 201-1 Aircraft Deicing Fluid  
**Status:** NetDMR Validated

**Report Dates & Status**  
**Monitoring Period:** From 11/01/23 to 11/30/23  
**DMR Due Date:** 12/31/23  
**Considerations for Form Completion**

**Principal Executive Officer**  
**First Name:** Thomas  
**Last Name:** Rafter  
**Title:** Executive Director  
**Telephone:** 203-466-8833

**No Data Indicator (NODI)**  
**Form NODI:** --

Code	Parameter Name	Monitoring Location	Season #	Param. NODI	Quantity or Loading			Quality or Concentration			# of Ex.	Frequency of Analysis	Sample Type
					Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3	Value 3			
00056	Flow rate	1 - Effluent Gross	0	--	Sample Value NODI	42655.8	07 - gal/d					01/30 - Monthly	TM - TOTAL
					Permit Req. Value NODI	Req Mon MO AVG	07 - gal/d					01/30 - Monthly	TM - TOTAL
00310	BOD, 5-day, 20 deg. C	1 - Effluent Gross	0	--	Sample Value NODI	193.65	26 - lb/d		2343.0		4800.0	01/07 - Weekly	CP - COMPOS
					Permit Req. Value NODI	6000.0 DAILY MX	26 - lb/d		Req Mon MO AVG		Req Mon DAILY MX	01/07 - Weekly	CP - COMPOS
00400	pH	1 - Effluent Gross	0	--	Sample Permit Req. Value NODI					6.94	12 - SU	01/07 - Weekly	R4 - RING-4A
					Permit Req. Value NODI					6.0 INST MIN	12 - SU	01/07 - Weekly	R4 - RING-4A
00530	Solids, total suspended	1 - Effluent Gross	0	--	Sample Permit Req. Value NODI				20.7		19 - mg/L	01/30 - Monthly	CP - COMPOS
					Permit Req. Value NODI				Req Mon MO AVG		19 - mg/L	01/30 - Monthly	CP - COMPOS
50047	Flow, maximum during 24 hr period	1 - Effluent Gross	0	--	Sample Permit Req. Value NODI	7031.6	07 - gal/d					01/30 - Monthly	TM - TOTAL
					Permit Req. Value NODI	36000.0 DAILY MX	07 - gal/d					01/30 - Monthly	TM - TOTAL
61163	Propylene glycol, total	1 - Effluent Gross	0	--	Sample Permit Req. Value NODI				1465.8		19 - mg/L	01/07 - Weekly	CP - COMPOS
					Permit Req. Value NODI				Req Mon MO AVG		Req Mon DAILY MX	01/07 - Weekly	CP - COMPOS
61941	pH, maximum	1 - Effluent Gross	0	--	Sample Permit Req. Value NODI						12 - SU	99/99 - Continuous	CN - CONTIN
					Permit Req. Value NODI						12 - SU	99/99 - Continuous	CN - CONTIN
61942	pH, minimum	1 - Effluent Gross	0	--	Sample Permit Req. Value NODI					6.94	12 - SU	99/99 - Continuous	CN - CONTIN
					Permit Req. Value NODI					6.0 INST MIN	12 - SU	99/99 - Continuous	CN - CONTIN
74076	Flow	1 - Effluent Gross	0	--	Sample Permit Req. Value NODI	7031.6	07 - gal/d					01/07 - Weekly	TM - TOTAL
					Permit Req. Value NODI	36000.0 DAILY MX	07 - gal/d					01/07 - Weekly	TM - TOTAL

