

Code	Parameter Name	Monitoring Location	Season #	Param. NODI		Quantity or Loading					Quality or Concentration						# of Ex.	Frequency of Analysis	Sample Type			
						Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3	Value 3				Units		
61941	pH, maximum	1 - Effluent Gross	0	--	Sample									=	8.1	12 - SU	99/99 - Continuous	CN - Continuous				
					Permit Req.											<=		10.0 INST MAX	12 - SU	CN - Continuous		
					Value NODI																	
61942	pH, minimum	1 - Effluent Gross	0	--	Sample					=	7.8					12 - SU	99/99 - Continuous	CN - Continuous				
					Permit Req.														>=	6.0 INST MIN	12 - SU	CN - Continuous
					Value NODI																	
74076	Flow	1 - Effluent Gross	0	--	Sample		=	4781.4	07 - gal/d								01/07 - Weekly	TM - Totalizer				
					Permit Req.		<=	36000.0 DAILY MX	07 - gal/d											01/07 - Weekly	TM - Totalizer	
					Value NODI																	
81017	Chemical Oxygen Demand [COD]	1 - Effluent Gross	0	--	Sample						=	1015.0	=	1900.0	19 - mg/L	01/07 - Weekly	CP - Composite					
					Permit Req.																01/07 - Weekly	CP - Composite
					Value NODI																	

Submission Note

If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors

No errors.

Comments

Attachments

No attachments.

Report Last Saved By

Tweed-New Haven Airport Authority

User: FSURIEL@FLYTWEED.COM
 Name: Felipe Suriel
 E-Mail: fsuriel@flytweed.com
 Date/Time: 2025-01-02 15:16 (Time Zone: -05:00)

Report Last Signed By

User: FSURIEL@FLYTWEED.COM
 Name: Felipe Suriel
 E-Mail: fsuriel@flytweed.com
 Date/Time: 2025-01-02 15:16 (Time Zone: -05:00)