This collection of information is approved by OMB under the Paperwork Reduction Act, 44 U.S.C. 3501 et seq. (OMB Control No. 2040-0004). Responses to this collection of information are mandatory in accordance with this permit and EPA NPDES regulations 40 CFR 122.41(I)(4)(i). An agency may not conduct or sponsor, and a person is not required to respond to, a collection of information unless it displays a currently valid OMB control number. The public reporting and recordkeeping burden for this collection of information are estimated to average 2 hours per outfall. Send comments on the Agency's need for this information, the accuracy of the provided burden estimates and any suggested methods for minimizing respondent burden to the Regulatory Support Division Director, U.S. Environmental Protection Agency (2821T), 1200 Pennsylvania Ave., NW, Washington, D.C. 20460. Include the OMB control number in any correspondence. Do not send the completed form to this address.

Permit

Permit #: CTP002421

Major: No

Permittee:

Permittee Address:

Tweed-New Haven Airport Authority

155 Burr Street

New Haven, CT 06512

Facility:

TWEED-NEW HAVEN REGIONAL AIRPORT

Facility Location: 155 BURR ST

NEW HAVEN, CT 06512

Permitted Feature:

201 External Outfall Discharge:

201-1

Aircraft Deicing Fluid

Report Dates & Status

Monitoring Period:

From 11/01/25 to 11/30/25

DMR Due Date:

12/31/25

Status:

NetDMR Validated

Considerations for Form Completion

Principal Executive Officer

First Name:

Thomas Rafter Title:

Executive Director

Telephone:

203-466-8833

No Data Indicator (NODI)

Form NODI:

Last Name:

--

	Parameter Monitoring Season Param.						Quantity or Loading						Q	uality or Conce				# of		Sample Type
Code	Name	Location	#	NODI		Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3	Value 3	Units	Ex.	Analysis	
00056	Flow rate				Sample	=	4430.0			07 - gal/d									01/30 - Monthly	TM - Totalizer
		1 - Effluent Gross	0		Permit Req.		Req Mon MO AVG			07 - gal/d									01/30 - Monthly	TM - Totalizer
					Value NODI															
00310	BOD, 5-day, 20 deg. C	1 - Effluent Gross			Sample			=	1539.8	26 - lb/d			=	39250.0	=	41000.0	19 - mg/L		01/07 - Weekly	CP - Composite
			0		Permit Req.			<=	6000.0 DAILY MX	26 - lb/d				Req Mon MO AVG		Req Mon DAILY MX	19 - mg/L		01/07 - Weekly	CP - Composite
					Value NODI															
	рН				Sample							6.7			=	6.8	12 - SU		01/07 - Weekly	R4 - RNG-4A
00400		1 - Effluent Gross	0		Permit Req.						>=	6.0 INST MIN			<=	10.0 INST MAX	12 - SU		01/07 - Weekly	R4 - RNG-4A
					Value NODI															
	Solids, total suspended	1 - Effluent Gross	0		Sample								=	13.5	=	15.0	19 - mg/L		01/30 - Monthly	CP - Composite
00530					Permit Req.									Req Mon MO AVG		Req Mon DAILY MX	19 - mg/L		01/30 - Monthly	CP - Composite
					Value NODI															
	Flow, maximum during 24 hr period	1 - Effluent Gross	0		Sample			=	4500.2	07 - gal/d									01/30 - Monthly	TM - Totalizer
50047					Permit Req.			<=	36000.0 DAILY MX	07 - gal/d									01/30 - Monthly	TM - Totalizer
					Value NODI															
61163	Propylene glycol, total	1 - Effluent Gross			Sample								=	22500.0	=	25000.0	19 - mg/L		01/07 - Weekly	CP - Composite
			0		Permit Req.									Req Mon MO AVG		Req Mon DAILY MX	19 - mg/L		01/07 - Weekly	CP - Composite
					Value NODI												5.			

	Parameter Name	Monitoring Location	Season	Param. NODI	Quantity or Loading							Quality or Concentration							Frequency of	Sample Type
Code			#			Qualifier 1	Value 1	Qualifie 2	r Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3	Value 3	Units	Ex.	Analysis	
61941	pH, maximum	1 - Effluent Gross			Sample										=	6.8	12 - SU		99/99 - Continuous	CN - Continuous
			0		Permit Req.										<=	10.0 INST MAX	12 - SU		99/99 - Continuous	CN - Continuous
					Value NODI															
61942	pH, minimum	1 - Effluent Gross			Sample						=	6.7					12 - SU		99/99 - Continuous	CN - Continuous
			0		Permit Req.						>=	6.0 INST MIN					12 - SU		99/99 - Continuous	CN - Continuous
					Value NODI															
74076	Flow				Sample			=	4500.2	07 - gal/d									01/07 - Weekly	TM - Totalizer
		1 - Effluent Gross	0		Permit Req.			<=	36000.0 DAILY MX	07 - gal/d									01/07 - Weekly	TM - Totalizer
					Value NODI															
81017	Chemical Oxygen Demand [COD]	1 - Effluent Gross			Sample								=	76750.0	=	88000.0	19 - mg/L		01/07 - Weekly	CP - Composite
			0		Permit Req.									Req Mon MO AVG		Req Mon DAILY MX	19 - mg/L		01/07 - Weekly	CP - Composite
					Value NODI															

Submission Note

If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors

No errors.

Comments

Attachments

No attachments.

Report Last Saved By

Tweed-New Haven Airport Authority

User: FSURIEL@FLYTWEED.COM

Name: Felipe Suriel

E-Mail: fsuriel@flytweed.com

Date/Time: 2025-12-03 11:48 (Time Zone: -05:00)

Report Last Signed By

User: FSURIEL@FLYTWEED.COM

Name: Felipe Suriel
E-Mail: fsuriel@flytweed.com

Date/Time: 2025-12-03 11:49 (Time Zone: -05:00)